

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
Ranchi Road, P.S. - Purulia(T), P.O. - Purulia, Pin - 732101**

Memo No : IND/WB/FES/20182019/47958

DATE: 01/06/2019

From :

**The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.**

To :

**Filix School of Education (an Educational Project of Nanritam).
Barandanga, P.O & P.S. Para,
Raghunathpur F.S., Para,
Purulia - 723155 .**

Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 storied building under group Educational at the premises no.-Filix School of Education (an Educational Project of Nanritam) Barandanga, P.O & P.S. Para,Dist. Purulia PIN-723155

This is in reference to your Application No. IND/WB/FES/20182019/47958,dated 01/06/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 1 storied building under group Educational at the premises no.-Filix School of Education (an Educational Project of Nanritam) Barandanga, P.O & P.S. Para,Dist. Purulia PIN-723155.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. At least 5,000lts water capacity terrace level water reservoir for only Fire Fighting purpose with replenishing arrangement @1000lts/min. preferably from two different sources

Filix School of Education
an Educational Project of Nanritam


Manager / Correspondent



PRINCIPAL
FILIX SCHOOL OF EDUCATION

of water supply shall be provided for fire fighting purpose. One electric and one diesel pump of mini. Capacity 900LPM shall be provided to supply requisite water pressure not less than 2kg/cm² at terrace level as well as Hose Reel system shall be arranged at each floor level, which shall be connected directly from the over head roof tank through automatically operated booster pump conforming the relevant IS specification, within three months from issue of the certificate

2. Minimum 4nos ABC (6kgs) and 2 Carbondioxide (4.5kgs) , Fire extinguisher shall be kept at each floor as well as Manual Call point shall be arranged within three months.

3. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.

4. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.

5. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and ducts.

6. A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.

7. The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.

8. The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.

9. Mock Fire practice and evacuation drill shall be performed periodically with participation of all teachers, employee and students of building.

10. Transformer and switchgear room shall be protected with automatic co₂ or DCP fire extinguisher conforming I.S specification.

11. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.

12. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.

13. The fire safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.


14. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.

15. Floor numbers and directional sign of escape route shall be displayed prominently.

16. This Fire Safety certificate is valid for three years and has to be renewed every three year from the date of issue of this letter.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid
Digitally signed by SUNIL
KUMAR CHAKRABORTY
Date: 2019.06.01 15:47:37 IST

Felix School of Education
an Educational Project of Nanritam

Manager / Correspondent

Shivan Lal Kimbhanse
PRINCIPAL
FILIX SCHOOL OF EDUCATION